



MINISTRY OF WATER, SANITATION & IRRIGATION

CENTRAL RIFT VALLEY WATER WORKS DEVELOPMENT AGENCY

CLARIFICATION NO.2 ON

Tender for

Procurement of Installation Works For Kampi Samaki Water Treatment Plant

Tender No: CRVWWDA/BAR/GOK /KAMPISAMAKI/WP/18/2024-2025

Employer: Central Rift Valley Water Works Development Agency (CRVWWDA), Nakuru, Kenya

FEBRUARY 2025

**PROCUREMENT OF INSTALLATION WORKS FOR KAMPI SAMAKI WATER TREATMENT PLANT
TENDER NO. CRVWDA/BAR/GOK /KAMPISAMAKI/WP/18/2024-2025**

Requests for Clarification and Responses – Part 1

No	Request for Clarification	Response
1	Kindly confirm if the prefilter unit of sand and carbon filters are required before the ultrafiltration unit since they are not stated on the specifications.	The contractor/supplier will determine this based on their designs.
2	Kindly confirm capacity and if Aeration Tank (T1), Sedimentation Tank (T2), Break Tank (T3) and Treated Tank (T4) will be provided by central rift water works development agency or contractor.	The client will provide the treated tank (T4); however, the contractor/supplier should specify and include the capacities of the remaining tanks based on their designs.
3	Please confirm if we can offer economical and efficient methodology of iron and manganese removal instead of oxidation system.	In addition to iron and manganese removal, other benefits of aeration were also considered. The contractor/supplier must adhere to the specified methodology.